

SG LAKHANPAL ASSOCIATES				SGLA/MOM/18Sep08
Minutes of Meeting				
Project : RK KHANNA TENNIS STADIUM FOR COMMONWEALTH GAMES 2010.				
Date of Meeting : SEPTEMBER 18, 2009				
Date of Issue of Notes : SEPTEMBER 21, 2009				
Venue of the Meeting : RK KHANNA TENNIS STADIUM CWG – 2010 SITE OFFICE				
Attendees: -				
1	Mr. Pradeep Dadwal, Manager	Member Working Committee, AITA CWG - 2010		
2	Mr. GN Lakhanpal, Principle Architect	SG Lakhanpal Associates		
3	Mr. Harish Panwar, Project Manager	SG Lakhanpal Associates		
4	Mr. Brij Mohan,	M/s Sai Solar Tanchno Pvt. Ltd		
5	Mr. Dharminder Singh, Manager Project Development & Execution	M/s Reliance Industries Limited (Solar Group)		
6	Mr. Umesh Kaushik, Asstt. Manager	M/s SHARP Business System (I) Ltd.		
7	Mr. Yasho Vir, CEO	M/s ARSH Electronics (P) Ltd.		
8	Mr. Jagdish Rawat, Manager Marketing	M/s Surana Telecom & Power Ltd. Bhagyanagar (I) Ltd.		
9	Mr. Sunil	M/s Surana Telecom & Power Ltd. Bhagyanagar (I) Ltd.		
10	Mr. Gourav Sethi	M/s Rajender Enterprises.		
S.N.	Description	Point Raised By	Remarks	Clarification
1	Extention for submission of the Tender up to 30th Sep, 2009 up 4 PM.	ALL BIDDERS		Allowed
2	Amendement in Eligibility Criteria may be considered for point no. 7.0/ 7.1 page no. 90 of Technical Bid - " we request our simillar work experience in corporate sector also in addition to center Govt./ Center Autonomus Body/ Central PSU's as indicated in Tender Document".	M/s SHARP Business System (I) Ltd.		Work experience in corporate sector may be allowed of Rs.9 Lakh. The bidders giving proof of experience in public sector would be given higher marking
3	Amendement in Eligibility Criteria may be considered - " If we have supplied solar lights of given value or more to any corporate sector, can we be considered for elisibility point of view".	M/s ARSH Electronics (P) Ltd.		Work experience in corporate sector may be allowed of Rs.9 Lakh. The bidders giving proof of experience in public sector would be given higher marking
4	Make of Power Conversion Unit (PCU) - our own make PCU meets all the requirements: may we supply the same.	M/s ARSH Electronics (P) Ltd.		List of approved makes will not be modified.
6	Make of PCU - "can we consider standard equivalent make PCUs other then DB & OPS?".	M/s Reliance Industries Limited (Solar Group)		List of approved makes will not be modified.
7	Make of Batteries - "can we consider standard equivalent make Batteries other then Exide & HBL?".	M/s Reliance Industries Limited (Solar Group)		List of approved makes will not be modified.
8	Can change in Junction Box Qty. as per our design is allowed.	M/s Reliance Industries Limited (Solar Group)		The bill of quantities cannot be modified. All may quote accordingly.
9	The location for mounting 3 nos. modules in Media Center roof top is not clearly mentioned in the drawing.	M/s Reliance Industries Limited (Solar Group)		The location has been shown physically on site.
10	What will be the approximate distance between rooftop and control room (for PCU & battery).	M/s Reliance Industries Limited (Solar Group)		Aprox. 40 MTR.

11	Module mounting structure should have either fixed angle or manual tilting arrangement for seasonal changes (winter/ summer)	M/s Reliance Industries Limited (Solar Group)		Fixed angle as per solar angle arrangement to be provided for seasonal changes. Bidders may quote accordingly.
12	If award of Tender can be split into two parts i.e. 'Supply of the various items as per the BOQ' and 'Design, installation & commissioning of the system'; this will result in saving on the part of taxation. The single contract design, supply, installation & commissioning will make the 80% of value under 12.5% tax slab & rest 20% of contract value under 10.3% slab.	M/s Reliance Industries Limited (Solar Group)		Tender conditions, scope of work will not be modified.
	General Note : At the time of quoting, bidders may highlight the benefits/ compensations which they make available from Ministry of Environment/Department of Renewable energy/ any other Government Ministry towards adopting this technology.			